

CERTIFICATE OF COMPLIANCE

Certificate Number EX16371
Report Reference EX16371-20201215
Date 2020-December-30

Issued to: BONPET SYSTEMS D.O.O.
Obrtniska Cesta 30
Trbovlje1420 SI

**This is to certify that
representative samples of**

WETTING AGENTS
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: NFPA 18, Wetting Agents

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number EX16371
Report Reference EX16371-20201215
Date 2020-December-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Products Covered:

Bonpet fire extinguishing liquid wetting agent concentrate, when added to water in concentrations of not less than 10% for Class A fires and not less than 15% for Class B fires



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

